



TOP OF ISLAND

SECTION THRU BASE

NOTES:

- 1- ALL PIPING AND ELECTRICAL INSTALLATIONS MUST CONFORM TO ALL APPLICABLE REGULATIONS INCLUDING NFPA30, FLAMMABLE & COMBUSTIBLE LIQUIDS CODE; NFPA30A, AUTOMOTIVE & MARINE SERVICE STATION CODE; NFPA70, NATIONAL ELECTRICAL CODE.
- 2- PIPING FROM TANK TO DISPENSER SHOULD SLOPE UPWARDS, AVOIDING AIR OR LIQUID TRAPS.
- 3- USE UNIVERSAL JOINTS AT DISPENSERS TO ALLOW FOR GROUND MOVEMENT.
- 4- CONDUIT TAPS SHOWN ARE PROVIDED, ANY OR ALL MAY BE USE TO MAKE ELECTRICAL CONNECTIONS TO DISPENSER.
- 5- FIRMLY MOUNT THE DISPENSER TO THE ISLAND USING THE ANCHOR BOLT LOCATIONS PROVIDED.
- 6- EMERGENCY SHUTOFF VALVES AND BREAKAWAY DEVICES ARE EXAMPLES OF REQUIREMENTS STATED IN THE NFPA30A, AUTOMOTIVE & MARINE SERVICE STATION CODE. THESE, AS WELL AS ANY OTHER SAFETY DEVICES REQUIRED BY NFPA30 & 30A, MUST BE INSTALLED AND MAINTAINED PER THE MANUFACTURER'S INSTRUCTIONS.

BASE DIMENSIONS 3/G2201D - 3/G2202D - 3/G2203D - 3/G2207D - 3/G2209D

MODEL - 3/G2209D - SHOWN

DWG NO: 3/G2209D
DATE: 10/20/2014
PROJECT: 2-305100-DWG A

DIVISION: WAYNE DIVISION
SCALE: 1/8" = 1'-0"

PROJECT NAME: 2-305100-DWG A

DATE	APP'D	CHK'D	DRN

REV

NO.	DESCRIPTION	DATE